



A P P R O V A L S ®

Certificate of Suitability

Addendum

Certificate No.: SAA183671

Date of Issue: 20 December 2018

Class Description: Non-Declared
Product Description: PV Grid Inverter

Additional Models

Description

MIN 5000TL-X

Input: 80-550Vdc, Max 550Vdc, Isc: 2x16A, Max 2x12.5A
Output: 230V~ 50Hz Max 22.7A 5000W, 5000VA

MIN 4600TL-X

Input: 80-550Vdc, Max 550Vdc, Isc: 2x16A, Max 2x12.5A
Output: 230V~ 50Hz Max 20.9A 4600W, 4600VA

MIN 4200TL-X

Input: 80-550Vdc, Max 550Vdc, Isc: 2x16A, Max 2x12.5A
Output: 230V~ 50Hz Max 19A 4200W, 4200VA

MIN 3600TL-X

Input: 80-550Vdc, Max 550Vdc, Isc: 2x16A, Max 2x12.5A
Output: 230V~ 50Hz Max 16A 3600W, 3600VA

MIN 3000TL-X

Input: 80-500Vdc, Max 500Vdc, Isc: 2x16A, Max 2x12.5A
Output: 230V~ 50Hz Max 13.6A 3000W, 3000VA

MIN 2500TL-X

Input: 80-500Vdc, Max 500Vdc, Isc: 2x16A, Max 2x12.5A
Output: 230V~ 50Hz Max 11.3A 2500W, 2500VA


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 20-12-18 183671/2